



Government Of West Bengal
Office Of The Director General
West Bengal Fire & Emergency Services
13D, Mirza Ghalib Street, Kolkata - 16

Memo no.:IND/WB/FES/20192020/50426

Date: 10-08-2022

From:
Divisional Fire Officer
Fire Prevention Wing,
West Bengal Fire & Emergency Services

To: FUTURE CAMPUS SCHOOL
P/7/2098 SONARPUR STATION ROAD,KOLKATA-700150

Sub: Renewal of Fire Safety Certificate (Conditional) for an existing occupancy of a G+III Storied Educational Building at Premises No.- P/7/2098 Sonarpur Station, Dist.- South 24 Paraganas, Pin- 700150.

This is in reference to your application no. 0125191221200164 dated 18-07-2022 regarding the Renewal of Fire Safety Certificate (Conditional) for an existing occupancy of a G+III Storied Educational Building at Premises No.- P/7/2098 Sonarpur Station, Dist.- South 24 Paraganas, Pin- 700150.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained:

Recommendation:

1. Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed.
2. The Interior finish decoration of the building shall be made with low flame spread material confirming to the I.S. specification.
3. To eliminate the risk of fire Hazards, Good House Keeping both for insides and outsides of the building shall be strictly maintained.
4. Existing Electrical wiring of the whole building shall have to be carefully checked for any wear & tear in them. Particularly

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the 'Verification of Digitally Signed Document' link and keying in the Unique Number : 0125191221200164.

Page : 1

Arif Saha
Principal

Arif Saha
Principal

Future Campus School
CBSE Affiliated Sr. Secondary School
Sonarpur, Kolkata

Powered By emSigner For secure paperless solutions
Please visit www.emsigner.com

lines above false ceiling & ducts.

5.A Fire Control room including a closed circuit T.V. system will have to be maintained which observes all floors of the building.

6.The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all vulnerable places of the building.

7.The employees and security staff shall be conversant with installed fire fighting equipment of the building and to operate in the event of the fire & testing.

8.Mock Fire Practice and Evacuation drill shall be performed periodically with participants of all the occupants of the building and record shall be kept in order.

9.Electrical mains, meter and panel room shall be protected with CO2 / D.C.P. Fire Extinction system conforming I.S. specification.

10.A trained fireman shall be maintained round the clock for safety of the building.

11.Arrangement shall have to be made for regular checking, testing and maintenance of all the fire fighting installation in the building to keep them in perfectly good working condition at all the times.

12.If required the old electrical lines shall have to be replaced with new lines. The cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.

13.This certificate is valid up to Third Floor of School Building except Fourth Floor and additional Six nos. different existing Building i.e (MBA Building (G+IV), Main Building (G+IV), Mechanical Building (G+III), Computer Application Building(G+III), Auditorium (G+M+I), Electrical Building (G+III)). In this regard Revised Fire Safety Recommendation to be obtained for regularization of above discrepancies through online e-district Portal with in 6 months from date of issue of this certificate.

14.Periodical flashing of water from water based suppression system shall be made to maintain the efficient working performance of above mentioned system.

15.The Fire Safety audit to be conducted at regular interval and to be recorded in the Fire Prevention maintenance register.

16.Fire Licence shall have to be obtained from Competent Authority for storing and processing with Commercial L.P.G and other highly Combustible articles.

17.Server Room to be protected with automatic CO2 & D.C.P Extinction Conforming I.S. Specification.

18.This Renewal of Fire Safety Certificate is valid for 6 months from date of issue of this memo as per prayer letter submitted in this office vide no 13049 dated 29/07/22. and has to be renewal within stipulated period.

19. A certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services regarding performance of all the Fire Safety arrangements and installations of the building.

Anthe S. Sanja

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the 'Verification of Digitally Signed Document' link and keying in the Unique Number : 0125191221200164.

Page : 2

Principal
Future Campus School
CBSE Affiliated Sr. Secondary School
Sonarpur Station Road, Kolkata-150

Prof. Subal Chandra

Powered By emSigner For secure paperless solutions
Please visit www.emsigner.com

Signature valid

Digitally signed by SAROJ
KUMAR B...
Date: 2022.08.10 18:53:01 IST

Divisional Fire Officer
West Bengal Fire & Emergency Services

Memo No. IND/WB/FES/201922/20/50426

Atul Chandra Choudhary

Anthe S. Singh

Principal
Future Campus School
CBSE Affiliated Sr. Secondary School
Sonarpur Station Road, Kolkata-150